ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

C E R T I F I C A T E

No. B 079567 0009 Rev. 00

Holder of Certificate: **F.A.E.S. di Bernacchi S. & C. S.n.c.**
Via Dagnano 3
52036 Pieve S. Stefano (AR)
ITALY

Certification Mark:

Product: **Float switches**
(Water level operating control)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier.
All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 6810022009301

Valid until: 2027-10-13

Date, 2022-10-14

(Richard Xu)

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

C E R T I F I C A T E

No. B 079567 0009 Rev. 00

Model(s): **JOLLY, TECNO, TECNO 2, MICRO, STRATOS**

Parameters:

JOLLY: 10(8)A, 250V~, 50-60Hz, IP68, T50, μ, 1E4
TECNO: 10(4)A, 250V~, 50-60Hz, IP68, T50, μ, 5E4
TECNO 2: 10(8)A, 250V~, 50-60Hz, IP68, T50, μ, 1E4
MICRO: 10(4)A, 250V~, 50-60Hz, IP68, T60, μ, 5E4
STRATOS: 10(8)A, 250V~, 50-60Hz, IP68, T50, μ, 5 Bar, 1E4

Tested according to: EN 60730-1:2016/A1:2019
EN IEC 60730-2-15:2019

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®